

**Exhibit 3-41 N**

**Daily Documentation for Temperature/Humidity in the Cleanroom Suite**

**Circle the location: Ante-area, Buffer-area**

Day	Room Temp / Checked by	Room Humidity / Checked by	If either or both parameters are not in range, contact Facilities Department to reset or as recommended by your Service Unit. Note the actions taken and the repeat measurements.	Day	Room Temp / Checked by	Room Humidity / Checked by	If either or both parameters are not in range, contact Facilities Department to reset or as recommended by your Service Unit. Note the actions taken and the repeat measurements.
1				17			
2				18			
3				19			
4				20			
5				21			
6				22			
7				23			
8				24			
9				25			
10				26			
11				27			
12				28			
13				29			
14				30			
15				31			
16							

Recommended ranges per USP 797: Temperature: 68°F or below (20°C or below); Humidity: less than 60%.