

Exhibit 3-41 O
Daily Pressure Differential Log

Month: _____ Year: _____

Day	Pressure Differential Between Ante-room and General Environment ^t	Pressure Differential Between Buffer Room and Ante-room ^t
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		

Out of Range Follow-up Documentation

Date	Time ID'ed	Location out of range	Action(s) taken	Follow-up temp reading	Time of Read	Initials

Not required on days when no compounding occurs. Not required for segregated compounding areas, but if design allows, it is advisable to record.

^t Pressure differential should be ≥ 0.02 -inch water column. Other requirements exist for compounding hazardous drugs (see Indian Health Manual Part 3 Chapter 7 and United States Pharmacopeia 800).